

**ALL PLANS ARE REVIEWED UNDER THE FOLLOWING CODES:**

- 1996 BOCA Basic National Building Code (Commercial, Industrial, Multi-Family)
- 1996 SBOC Suburban Building Officials Conference (1 and 2 Family Residential)
- 1996 National Electrical Code
- 2014 IL Plumbing Code

**§ 150.025 ADOPTION OF ELECTRICAL CODE BY REFERENCE; AMENDMENTS.**

(A) The National Electric Code, 1996 Edition, as amended, is hereby adopted by reference and incorporated as a part of this code as if fully set out herein. Amendments to the aforementioned 1996 edition are hereby adopted and incorporated by reference as part of this code as if fully set out herein, except that the following articles of the National Electric Code are not adopted: 331, 336, 342, 352-B, 545; and that certain articles of the National Electric Code be further amended as follows in division (B) of this section.

(B) The following articles of the National Electric Code, 1996 Edition, are hereby revised:

*Article 320, Open wiring on insulators*, delete text in its entirety and replace with the following:

“Open wiring shall not be permitted except as provided in Article 305.”

*Article 324, Concealed knob-and-tube wiring*, delete text in its entirety and replace with “Concealed knob-and-tube wiring shall not be permitted for any new installation. If exposed during remodeling or alternations or found to be faulty, it shall be replaced by an approved wiring method.”

*Article 333, Armored cable (BX)*, shall be deleted in its entirety and replaced with the following: “Armored cable (BX) is not allowed except for the following installations:

1. Lengths of not more than 2 feet at terminals where flexibility is necessary and installation is approved by the code official.

2. Lengths of not more than 6 feet from an outlet for connections within an accessible ceiling to lighting fixtures or equipment.”  
(Ord. 0-97-45, passed 12-8-97)

**§ 150.026 SPECIFIC REGULATIONS.**

(A) All service entrance conductor wires are to be run in rigid or intermediate galvanized steel conduit.

(B) All electrical work shall be performed by a licensed electrician except as follows: A homeowner may do electrical work in his own single-family dwelling.

(C) All wire conductors shall be copper.

(D) Service entrance equipment to be installed to meet the requirements of the electric supply company providing it does not conflict with any other section of this subchapter.  
(Ord. 0-97-45, passed 12-8-97)